

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1597:125

Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: TEPG-US, 91 Technology Dr, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Model T372-9803 SmartSync Adapter Module. Unit allows conventional notification appliances to be operated on a SmartSync notification appliance circuit. The adapter can employ either one audible and one visual appliance or one combination audible/visual unit. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a control unit accessory for use with listee's separately listed Model T310-9301 series (CSFM Listing No. 7170-1597:116) fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLf: 7300-0026:315

04-09-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 9, 2004**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager